



Case Study Using XML over HTTP to monitor and control Using QuickServer / FieldServer products






How Gateways Work - Sharing Data Using Internal Data Arrays

Different protocols address data objects differently. That is why you cant take a message from one protocol and automatically convert it to a message in another protocol. Modbus would though up its hands in despair if you asked it for Mutli_State_Input(19001) from Device 389001. BACnet has no idea what a Holding Register is. This is why gateways need configuration — a map — that maps data objects of the one protocol to data objects in another protocol. It also means that gateways need to cache data (in Data Arrays) and that each item in storage can be identified (in the map) by two addresses — one for each protocol.





You can use XML to Read and Write this Shared Data





XML Read Request

http://192.168.1.5/data_arrays.xml?name=FIRE1234.0:100


192.168.1.5 = Remote Server IP Address, Configurable from settings file.

FIRE1234 = DataArray name in gateway

0:100 = x:y

X = Offset into DataArray

y = Number of Items to read from DataArray





XML Write Response

This is the response for the above request example

<DATA_ARRAYS FST_XML_VERSION="1.00" MAX_INDEX="1" BRIDGE_TITLE="SBT FSI SERVER">

<DATA_ARRAY NAME="FIRE1234" FORMAT="BIT" LENGTH="100" INDEX="1">

<DATA OFFSET="0" DATA AGE="3:00:39.36.123s" STATUS="0" >

</DATA ARRAY>

<DATA_ARRAYS>

