



Rapid Engineering ICS-I & ICS-II Driver Manual FS-8700-106

Chipkin - Enabling Integration

salesgroup1@chipkin.com

Tel: +1 866 383 1657

© 2021 CHIPKIN AUTOMATION SYSTEMS

Driver Version: 1.00f
Document Revision: 1

TABLE OF CONTENTS

| | |
|---|-----------|
| TABLE OF CONTENTS | 2 |
| 1 ICSI AND ICSII DRIVER DESCRIPTION | 3 |
| 2 DRIVER SCOPE OF SUPPLY | 4 |
| 2.1 SUPPLIED BY FIELDSEVER TECHNOLOGIES FOR THIS DRIVER..... | 4 |
| 2.2 PROVIDED BY THE SUPPLIER OF 3 RD PARTY EQUIPMENT | 4 |
| 2.2.1 <i>Required 3rd Party Hardware</i> | 4 |
| 2.2.2 <i>Required 3rd Party Software</i> | 4 |
| 2.2.3 <i>Required 3rd Party Configuration</i> | 4 |
| 3 HARDWARE CONNECTIONS..... | 5 |
| 3.1 HARDWARE CONNECTION TIPS / HINTS | 7 |
| 4 CONFIGURING THE FIELDSEVER AS AN ICS1/2 CLIENT | 8 |
| 4.1 DATA ARRAYS/DESCRIPTORS | 8 |
| 4.2 CLIENT SIDE CONNECTION DESCRIPTIONS..... | 9 |
| 4.3 CLIENT SIDE NODE DESCRIPTORS..... | 10 |
| 4.4 CLIENT SIDE MAP DESCRIPTORS | 11 |
| 4.4.1 <i>FieldServer Related Map Descriptor Parameters</i> | 11 |
| 4.4.2 <i>Driver Related Map Descriptor Parameters</i> | 11 |
| 4.4.3 <i>Timing Parameters</i> | 12 |
| 4.4.4 <i>Map Descriptor Example 1 – Read Everything</i> | 13 |
| 4.4.5 <i>Map Descriptor Example 2 – Read Specific</i> | 14 |
| 4.4.6 <i>Map Descriptor Example 3 – Write Continuously</i> | 15 |
| 4.4.7 <i>Map Descriptor Example 4 – Write on Update</i> | 16 |
| 5 CONFIGURING THE FIELDSEVER AS A (ICS1/2 DRIVER) SERVER | 17 |
| 6 REVISION HISTORY | 18 |
| APPENDIX A - ADVANCED TOPICS..... | 20 |
| APPENDIX A.1. APPLICATION = CLIENT | 20 |
| APPENDIX B. DRIVER NOTES..... | 22 |
| APPENDIX B.1. MAP DESCRIPTOR LENGTHS | 22 |
| APPENDIX B.2. ICS1/2_FUNCTION AND DATA STORAGE LOCATIONS | 22 |
| APPENDIX B.3. FIELDSEVER NODE NUMBER | 34 |
| APPENDIX C. TROUBLESHOOTING TIPS..... | 35 |
| APPENDIX C.1. CONNECTION TIPS & HINTS..... | 35 |
| APPENDIX C.2. DRIVER ERROR MESSAGES | 35 |

1 ICSI and ICSII Driver Description

This driver is used to exchange data between a FieldServer and an ICSI or ICSII HVAC controller device.

The driver is a serial driver using a RS485 serial port to connect between the FieldServer and the ICS1/2 capable device.

The driver provides client functionality.

As a client the driver can poll for data from the ICS1/2 device as well as being able to some control points and set points. Details are provided below.

Server functionality is built into the driver but is not documented or supported. This functionality is implemented to support our ongoing QC efforts.

The driver is fully compatible with other FieldServer drivers and meets FieldServer's quality assurance standards. The driver was developed by Chipkin Automation Systems, an Approved FieldServer Integrator. Please contact Chipkin Automation System directly for support.

Max Nodes Supported

| FIELDSEVER MODE | NODES | COMMENTS |
|-----------------|-------|--|
| Client | 99 | Up to 99 ICS1/2 devices can be linked on one RS485 network. The functional specification of the EIA485 standard limits the number of nodes per segment to 32. If additional network segments are required then repeaters are required. |
| | | |

2 Driver Scope of Supply

2.1 Supplied by FieldServer Technologies for this driver

| FIELDSEVER TECHNOLOGIES PART # | DESCRIPTION |
|--------------------------------------|-------------------------------------|
| | |
| | |
| FS-8917-16 | RJ-45 Pigtail for RS-485 connection |
| | |
| - | Driver Manual. |
| | |

2.2 Provided by the Supplier of 3rd Party Equipment

2.2.1 Required 3rd Party Hardware

| PART # | DESCRIPTION |
|--------|-------------|
| | |

2.2.2 Required 3rd Party Software


No 3rd Party software is required.

2.2.3 Required 3rd Party Configuration

Please contact your vendor for configuration information,

We note that at a minimum the following configuration activities must be performed.


1. Set End of Line switch
2. Connect to P6 on the ICS1/2 Board
3. Set the address on the "ADDRESSING" Switch.




3 Hardware Connections

The FieldServer is connected to the ICS1/2 as shown in connection drawing.

Configure the ICS1/2 according to manufacturer's instructions






3.1 Hardware Connection Tips / Hints

The Red flashing LED located adjacent to connector P^ on the ICS1/2 board flashes when data is transmitted.

The green LED on the ICS1/2 board should flash periodically, This is the board health indicator,



If more than one ICS1/2 boards are connected on a single network then the END of LINE switch adjacent to port P6 must be set correctly. Your vendor can provide more information on the correct settings,

4 Configuring the FieldServer as an ICS1/2 Client

For a detailed discussion on FieldServer configuration, please refer to the FieldServer Configuration Manual. The information that follows describes how to expand upon the factory defaults provided in the configuration files included with the FieldServer (See “.csv” sample files provided with the FS).

This section documents and describes the parameters necessary for configuring the FieldServer to communicate with a ICS1/2 device.

4.1 Data Arrays/Descriptors

The configuration file tells the FieldServer about its interfaces, and the routing of data required. In order to enable the FieldServer for (ICS1/2 Driver) communications, the driver independent FieldServer buffers need to be declared in the “Data Arrays” section, the destination device addresses need to be declared in the “Client Side Nodes” section, and the data required from the servers needs to be mapped in the “Client Side Map Descriptors” section. Details on how to do this can be found below.

Note that in the tables, * indicates an optional parameter, with the bold legal value being the default.

| SECTION TITLE | | |
|-------------------|--|---|
| Data_Arrays | | |
| COLUMN TITLE | FUNCTION | LEGAL VALUES |
| Data_Array_Name | Provide name for Data Array | Up to 15 alphanumeric characters |
| Data_Array_Format | Provide data format. Each Data Array can only take on one format. | Float, Bit, UInt16, SInt16, Packed_Bit, Byte, Packed_Byte, Swapped_Byte |
| Data_Array_Length | Number of Data Objects. Must be larger than the data storage area required by the Map Descriptors for the data being placed in this array. | 1-10,000 |

Example

```
// Data Arrays
Data_Arrays
Data_Array_Name,      Data_Format,      Data_Array_Length,
DA_AI_01,             UInt16,           200
DA_AO_01,             UInt16,           200
DA_DI_01,             Bit,              200
DA_DO_01,             Bit,              200
```


4.2 Client Side Connection Descriptions

| SECTION TITLE | | |
|-----------------------|---|--|
| Connections | | |
| COLUMN TITLE | FUNCTION | LEGAL VALUES |
| Port | Specify which port the device is connected to the FieldServer | P1-P8, R1-R2 ¹ |
| Protocol | Specify protocol used | icsii |
| Baud* | Specify baud rate | Driver Supports : 110; 300; 600; 1200; 2400; 4800; 9600 ; 19200; 28800; 38400; 57600; 115200 Baud Vendor Equipment support 9600 Baud |
| Parity* | Specify parity | Even, Odd, None , Mark, Space |
| Data_Bits* | Specify data bits | 7, 8 |
| Stop_Bits* | Specify stop bits | 1 |
| Handshaking* | Specify hardware handshaking | RTS, RTS/CTS, None |
| Poll_Delay* | Time between internal polls | 0-32000 seconds, 1 second |
| Application* | Please read the notes in Appendix A.1 | |
| ICS_Firmware_version* | For ICSII controllers do not specify this parameter. For ICS1 or 310 systems you must specify this parameter and set the value to a whole number. All ICS nodes on the connection are assumed to be of the same type or have the same firmware. | 1 (for ICS1 or 310 Systems) |
| ICS_Consume_Nulls* | Specify this parameter if you think there is noise on the line. It isn't uncommon for messages from the ICS controller to be | Yes, No |

¹ Not all ports shown are necessarily supported by the hardware. Consult the appropriate Instruction manual for details of the ports available on specific hardware.

| | | |
|--|---|--|
| | <p>preceded ro followed by a null character.</p> <p>When specified and when the parameter value is set to Yes, the driver consumes and discards null bytes so they do not interfere with the interpretation of messages</p> | |
| | | |

Example

```
// Client Side Connections

Connections
Port,      Port,      Port,      Port,      Port,      Port,
R1,       R1,       R1,       R1,       R1,       R1,
```

4.3 Client Side Node Descriptors

| SECTION TITLE | | |
|---------------|---|----------------------------------|
| Nodes | | |
| COLUMN TITLE | FUNCTION | LEGAL VALUES |
| Node_Name | Provide name for node | Up to 32 alphanumeric characters |
| Node_ID | Modbus station address of physical server node | 1-99 |
| Protocol | Specify protocol used | ICSII. |
| Connection | Specify which port the device is connected to the FieldServer | P1-P8, R1-R2 ² |

² Not all ports shown are necessarily supported by the hardware. Consult the appropriate Instruction manual for details of the ports available on specific hardware.

Example

```
// Client Side Nodes

Nodes
Node_Name          Node_ID          Protocol          Connection
PLC 1              1              ICSII            R1
```

4.4 Client Side Map Descriptors

4.4.1 FieldServer Related Map Descriptor Parameters

| COLUMN TITLE | FUNCTION | LEGAL VALUES |
|---------------------|--|---|
| Map_Descriptor_Name | Name of this Map Descriptor | Up to 32 alphanumeric characters |
| Data_Array_Name | Name of Data Array where data is to be stored in the FieldServer | One of the Data Array names from "Data Array" section above |
| Data_Array_Offset | Starting location in Data Array | 0 to maximum specified in "Data Array" section above |
| Function | Function of Client Map Descriptor | RDBC, WRBC, WRBX |

4.4.2 Driver Related Map Descriptor Parameters

| COLUMN TITLE | FUNCTION | LEGAL VALUES |
|--------------|---|---|
| Node_Name | Name of Node to fetch data from | One of the node names specified in "Client Node Descriptor" above |
| Length | Length of Map Descriptor | 1,2 ,3 etc ... See Table Appendix B.1 |
| Address | This commonly used parameter is not used by this driver. You can set its value to zero. | 0 |

| | | |
|-----------------------|--|--|
| <p>ICSII_Function</p> | <p>The name of the function that must be executed when the poll is sent.</p> <p>Each ICS1/2 function reads a different set of data.</p> <p>Some are used to write to the ICS1/2 devices.</p> <p>If you are only interested in reading data and are happy with the driver's default poll rates then use the simple function "Read All Reports"</p> <p>To determine what each function reads/ writes read section Appendix B.2</p> <p>Those functions marked with an * are not available on ICS1 or 310 systems.</p> | <ul style="list-style-type: none"> • Read All Reports • Heater Status Report • Setpoints Report • Occupied Sched Report* • Aux Output Sched Report • Setpoint Range Report • Error reset latch Report • Energy information • Configuration * • Change Mode • Change Setpoint • Change Schedule Air Handler • Set Aux Output Schedule* • Zero energy counters • Set Aux Output Setpoint* |
|-----------------------|--|--|


4.4.3 Timing Parameters

| COLUMN TITLE | FUNCTION | LEGAL VALUES |
|---------------|------------------------------|--------------|
| Scan_Interval | Rate at which data is polled | ≥0.001s |

4.4.4 Map Descriptor Example 1 – Read Everything.

This single Map Descriptor reads all the data that can be read from an ICS1/2 controller. One of these is required for each controller you read from. The command performs each type of read but reads the ‘Heater Report’ more often than say the ‘Configuration’ report. The driver has allocated a default frequency to each report. The relative frequency cannot be changed but the scan interval can be changed. Read Appendix B.2 for information on where the data is stored. Please also read the notes in Appendix A.1 which provide an outline on how to simplify the configuration.

| Map_Descriptor_Name, | Data_Array_Name, | Data_Array_Offset, | Function, | ICSII_Function, | Node_name | Address | Length | Scan_Interval |
|----------------------|------------------|--------------------|-----------|-------------------|-----------|---------|--------|---------------|
| ReadAll, | DA_UNIT1, | 0, | RDBC, | Read All Reports, | UNIT1, | 0, | 345, | 1.0s |



_*

4.4.5 Map Descriptor Example 2 – Read Specific.

If you want to 1) Read only a specific data set and / or 2) read one set of data more frequently than done by the ‘Read All Reports’ function then add a Map Descriptor for each specific command. You can combine Map Descriptors like the ones in this example with the Map Descriptor in example 1 without a problem..

| Map_Descriptor_Name, | Data_Array_Name, | Data_Array_Offset, | Function, | ICSII_Function, | Node_name | Address | Length | Scan_Interval |
|----------------------|------------------|--------------------|-----------|-------------------|-----------|---------|--------|---------------|
| ReadSetpoints, | DA_UNIT1, | 23, | RDBC, | Setpoints Report, | UNIT1, | 0, | 18, | 1.0s |

When Data is stored it is always done relative to offset zero. This parameter is not used in determining the storage location of data.

However, it used by the FieldServer in determining which MD owns a section of a Data Array. For this reason an offset is specified.

Suggested offsets are obtained from Appendix B.1

In this case reads the values of Setpoints in the ICSII controller.

Set the Address to zero in all cases,

Length is obtained from Appendix B.1 **Error! Reference source not found.**

4.4.6 Map Descriptor Example 3 – Write Continuously.

This map descriptor changes the controller’s mode by writing the value found at offset 301 in the Data Array named “DA_UNIT1”. The offset where the new mode number will be found was determined by inspection of the Appendix B.2.. The value found at offset 300 is ignored when the write is done continuously.

| Map_Descriptor_Name, | Data_Array_Name, | Data_Array_Offset, | Function, | ICSII_Function, | Node_name | Address | Length | Scan_Interval |
|----------------------|------------------|--------------------|-----------|-----------------|-----------|---------|--------|---------------|
| SetMode, | DA_UNIT1, | 300, | WRBC, | Change Mode, | UNIT1, | 0, | 2, | 1.0s |

When Data is extracted from a Data Array for a write it is always done relative to offset zero. This parameter is not used in determining the extraction location of data.

However, it used by the FieldServer in determining which MD owns a section of a Data Array. For this reason an offset is specified.

Suggested offsets are obtained from **Error! Reference source not found.**

Tells the driver to write continuously.

Tells the driver to issue the ‘Change Mode’ command.

Set the Address to zero in all cases,

Length is obtained from **Error! Reference source not found.**

4.4.7 Map Descriptor Example 4 – Write on Update.

This map descriptor changes the controller’s mode by writing the value found at offset 301 in the Data Array named “DA_UNIT1”. The offset where the new mode number will be found was determined by inspection of the Appendix B.2

The offset on the MD has been set to 300. This is the trigger offset. The way that a write on update should work is as follows:- The remote device write the values used by the command (a single value at offset 300 for the Change Mode command) then the remote device should write a ‘1’ to the trigger offset. This will trigger the write.

| Map_Descriptor_Name, | Data_Array_Name, | Data_Array_Offset, | Function, | ICSII_Function, | Node_name | Address | Length | Scan_Interval |
|----------------------|------------------|--------------------|-----------|-----------------|-----------|---------|--------|---------------|
| SetMode, | DA_UNIT1, | 300, | WRBX, | Change Mode, | UNIT1, | 0, | 1, | 1.0s |

When Data is extracted from a Data Array for a write it is always done relative to offset zero. This parameter is not used in determining the extraction location of data.

However, it used by the FieldServer in determining which MD owns a section of a Data Array and in the case of write on update it used by the FieldServer to determine which Data Array locations must be watched for an update.

Tells the driver to write on update. Update is not the same as change. An update occurs each time a remote device write to the offset(s) specified.

Tells the driver to issue the ‘Change Mode’ command.

Set the Address to zero in all cases,

Length is set to 1 when you write on update.

5 Configuring the FieldServer as a (ICS1/2 Driver) Server

A server side of the driver has been developed. It can be used to emulate an ICS1/2 device from a data (and not a functionality) point of view. The server was developed to allow the driver to meets FieldServer's Quality Assurance efforts. It is not supported or documented, If you are interested in using the server then please contact the FST sales group.

6 Revision History

| DATE | RESP | FORMAT | DRIVER VER. | DOC. REV. | COMMENT |
|--------------|------|--------|-------------|-----------|--|
| 18 Jun 2004 | PMC | PMC | 1.00a | 0 | Document Created |
| 23 Sept 2004 | PMC | PMC | 1.00c | 0 | <p>Section 4.2 _ Notes on new connection parameters 'ICS_Consume_Nulls' and 'ICS_Firmware_version'</p> <p>Appendix A.1 Notes on how Map Descriptor auto creation is affected by the parameter 'ICS_Firmware_version'</p> <p>Appendix B.1 Notes on which functions are supported for ICS1 and 310 systems</p> <p>Appendix B.2 Notes on which Data Array locations are supported for ICSII, ICS1 and 310 systems</p> |
| 17 Dec 2004 | PMC | PMC | 1.00d | 0 | <p>Appendix B.2 Schedule Data: Notes explain how this data is multiplexed. The period numbers for the most recent read are stored at offsets 270, 271. The driver automatically reads successive period data.</p> <p>Appendix B.2 Added info on broadcasting the date and time to all the ICS units.</p> <p>Appendix B.2 Added notes on how energy information is written.</p> <p>Appendix B.2 Added notes on how energy information is read.</p> <p>Appendix B.2 Added notes on how to interpret the current state reported at offset 7</p> <p>Appendix C.2 Added Msgs.</p> |
| 21 Jan 2005 | PMC | PMC | 1.00f | 0 | <p>Appendix B.2 Schedule Data: Notes explain how this data is multiplexed. The period numbers for the most recent read are stored at offsets 270, 271. but in addition the driver sets one of the following offstes non-zero and the others zero to indicate the period – 272,273,274,275,276,277 (for Schedule data) and 278,279,280,281,282,283 (for aux sched data) .</p> |

| | | | | | |
|-------------|----|----|-------|---|----------------------------|
| 10 May 2021 | YC | YC | 1.00f | 1 | Updated to latest template |
|-------------|----|----|-------|---|----------------------------|

APPENDIX A - Advanced Topics

Application Specific Operation

This driver supports an FST technology known as Application Specific Operation. This means by using certain keywords the user can simplify the configuration effort.

Appendix A.1. Application = Client

By specifying the application as Client you do not have to create any DA's or Map Descriptors. The driver will do it for you. All that is required is a connection a a node definition for each ICS1/2 device. The driver will create a single Data Array and multiple Map Descriptors to read all the data and to facilitate a write of any set point or mode.

Example

```
// Client Side Connections

Connections
Port,          Protocol,          Baud,  Application  Port,          Protocol,
R1,            icsii,            9600,  Client       R1,            icsii,
```

```
// Client Side Nodes

Nodes
Node_Name      Node_ID      Protocol      Connection
HTR_01         1            ICSII         R1
```

A single Data Array called "DA_HTR_01" is created It is named for the node name. One DA is created for each node.

8 Map Descriptors are created. One which reads everything and 7 which can be used to write tot the device. The listing below provides details of the MDs that will be created. (If the ICS_Firmware_version parameter has been specified on the connection then those MD's marked with a * are not created.)

Map_Descriptors

Map_Descriptor_Name , Scan_Interval , Data_Array_Name , Data_Array_Offset , Node_Name , Function , ICSII_Function , Address , Length
 ReadAll_Htr_01 , 0s , DA_HTR_1 , 0 , Htr_01 , Rdbc , Read Everything , 0 , 300

Map_Descriptors

Map_Descriptor_Name , Scan_Interval , Data_Array_Name , Data_Array_Offset , Length , Node_Name , Function , ICSII_Function , Address ,
 Cmd08_Htr_01 , 0s , DA_HTR_1 , 300 , 1 , Htr_01 , wrbx , Change Mode , 300 ,
 Cmd09_Htr_01 , 0s , DA_HTR_1 , 302 , 1 , Htr_01 , wrbx , Change Setpoint , 302 ,
 Cmd10_Htr_01 , 0s , DA_HTR_1 , 305 , 1 , Htr_01 , wrbx , Change Schedule Air Handler , 305 ,
 Cmd20_Htr_01* , 0s , DA_HTR_1 , 313 , 1 , Htr_01 , wrbx , Set Aux Output Schedule , 313 ,
 Cmd11_Htr_01 , 0s , DA_HTR_1 , 321 , 1 , Htr_01 , wrbx , Zero energy counters , 321 ,
 Cmd13_Htr_01* , 0s , DA_HTR_1 , 324 , 1 , Htr_01 , wrbx , Set Aux Output Setpoint , 324 ,
 Cmd07_Htr_01 , 0s , DA_HTR_1 , 328 , 1 , Htr_01 , wrbx , Energy information , 328 ,

Appendix B. Driver Notes

Appendix B.1. Map Descriptor Lengths

This table provides the 'Length' parameter that must be specified on a Map Descriptor's definition.

This table provides the 'Data_Array_Offset' parameter that must be specified on a Map Descriptors definition

Functions marked with a * are not supported by ICS1 or 310 systems and therefore the Data Array locations are not updated by the driver.

| ICSII_Function | Length | Offset |
|---|--------|--------|
| Read All Reports | 345 | 0 |
| Heater Status Report | 23 | 0 |
| Setpoints Report | 18 | 23 |
| Occupied Sched Report | 30 | 41 |
| Aux Output Sched Report* | 30 | 71 |
| Setpoint Range Report | 22 | 101 |
| Error reset latch Report | 24 | 123 |
| Energy information (Read) | 16 | 147 |
| Configuration * | 26 | 238 |
| Change Mode | 2 | 300 |
| Change Setpoint | 3 | 302 |
| Change Schedule Air Handler | 8 | 305 |
| Set Aux Output Schedule* | 8 | 313 |
| Zero energy counters | 3 | 321 |
| Set Aux Output Setpoint* | 4 | 324 |
| Energy information (Write) | 6 | 328 |
| Set Date and Time (Broadcast to all nodes) | 6 | 335 |

Appendix B.2. ICS1/2_Function and Data Storage Locations

This table does three things

- 1) Provides a list of permitted “ICSII_Function” parameter keywords
- 2) Tells you what data each function reads / writes
- 3) Tells you where read data is stored and where written data is extracted from.

Read Functions

The following functions read data from the ICS1/2 and store data at the location specified in the “DA Offset” column,

| FUNCTION | PARAMETER | NOTES | DA OFFSET | DESCRIPTION |
|----------------------|-----------|-------|-----------|---|
| Heater Status Report | 1 | | 0 | Day of Week |
| Heater Status Report | 2 | | 1 | Date (MM) |
| Heater Status Report | 2 | | 2 | Date (DD) |
| Heater Status Report | 2 | | 3 | Date (YY) |
| Heater Status Report | 3 | | 4 | Time HH |
| Heater Status Report | 3 | | 5 | Time MM |
| Heater Status Report | 4 | | 6 | Mode |
| Heater Status Report | 5 | | 7 | Current state States 1,2,3,4,5,12,14,15 the fan is on. States 2,5,12,14,15 the burner is on. State 1, relief is on. |
| Heater Status Report | 6 | | 8 | Current space temp setpoint |
| Heater Status Report | 7 | | 9 | Space temp |
| Heater Status Report | 8 | | 10 | Discharge temp |
| Heater Status Report | 9 | | 11 | Outside air temp |
| Heater Status Report | 10 | | 12 | Pressure setpoint |
| Heater Status Report | 11 | | 13 | Pressure |
| Heater Status Report | 12 | | 14 | Outside air damper |
| Heater Status Report | 13 | | 15 | Return air damper |
| Heater Status Report | 14 | | 16 | Inputs A single value is stored. Each bit in the value represents an input. Eg value=65520(decimal) = FFF0(hexadecimal) which is inputs 0-3 off and all others on. |
| Heater Status Report | 15 | | 17 | Outputs |

| | | | | |
|-----------------------|-----|---|-----|---|
| Heater Status Report | 16 | | 18 | Current error |
| Heater Status Report | 17 | 1 | 19 | Space relative humidity |
| Heater Status Report | 18 | 1 | 20 | Valve position |
| Heater Status Report | 19 | 1 | 21 | Future |
| Heater Status Report | 20 | 1 | 22 | Future |
| | | | | |
| Setpoints Report | 1 | | 23 | Occupied temperature |
| Setpoints Report | 2 | | 24 | Unoccupied temperature |
| Setpoints Report | 3 | | 25 | Maximum discharge temperature |
| Setpoints Report | 4 | | 26 | Minimum discharge temperature |
| Setpoints Report | 5 | | 27 | Building pressure |
| Setpoints Report | 6 | | 28 | Occupied burner turnoff |
| Setpoints Report | 7 | | 29 | Unoccupied heater turnoff |
| Setpoints Report | 8 | | 30 | Occupied open relief times |
| Setpoints Report | 9 | | 31 | Unoccupied open relief times |
| Setpoints Report | 10 | | 32 | Low temperature shutdown |
| Setpoints Report | 11 | | 33 | Percent outside air |
| Setpoints Report | 12 | | 34 | Burner turnoff setpoint enable//disable(1=Enable) |
| Setpoints Report | 13 | | 35 | Outside air temp. control enable//disable(1=Enable) |
| Setpoints Report | 14 | 1 | 36 | Room relative humidity setpoint |
| Setpoints Report | 15 | 1 | 37 | Dry-bulb economizer setpoint |
| Setpoints Report | 16 | 1 | 38 | Econ type (0-1-2) none- dry-bulb- enthalpy |
| Setpoints Report | 17 | 1 | 39 | Future |
| Setpoints Report | 18 | 1 | 40 | Future |
| | | | | |
| Occupied Sched Report | N/A | 2 | 270 | Period Number for most recent read Contains a numeric value 1,5,9,13,17 or 21 indicating how the following parameters should be interpreted. |
| | | | 272 | Set to 1 when Period number is 1,2,3,4. Else set to zero by driver |
| | | | 273 | Set to 1 when Period number is 5,6,7,8. Else set to zero by driver |

| | | | | |
|-----------------------|---|---|-----|--|
| | | | 274 | Set to 1 when Period number is 9,10,11,12. Else set to zero by driver |
| | | | 275 | Set to 1 when Period number is 13,14,15,16. Else set to zero by driver |
| | | | 276 | Set to 1 when Period number is 17,18,19,20. Else set to zero by driver |
| | | | 277 | Set to 1 when Period number is 21. Else set to zero by driver |
| Occupied Sched Report | 1 | 2 | 41 | Period(1-5-9-13-17)- start D |
| Occupied Sched Report | 1 | 2 | 42 | Period(1-5-9-13-17)- start HH |
| Occupied Sched Report | 1 | 2 | 43 | Period(1-5-9-13-17)- start MM |
| Occupied Sched Report | 2 | 2 | 44 | Period(1-5-9-13-17)- stop D |
| Occupied Sched Report | 2 | 2 | 45 | Period(1-5-9-13-17)- stop HH |
| Occupied Sched Report | 2 | 2 | 46 | Period(1-5-9-13-17)- stop MM |
| Occupied Sched Report | 3 | 2 | 47 | Period(2-6-10-14-18)- start D |
| Occupied Sched Report | 3 | 2 | 48 | Period(2-6-10-14-18)- start HH |
| Occupied Sched Report | 3 | 2 | 49 | Period(2-6-10-14-18)- start MM |
| Occupied Sched Report | 4 | 2 | 50 | Period(2-6-10-14-18)- stop D |
| Occupied Sched Report | 4 | 2 | 51 | Period(2-6-10-14-18)- stop HH |
| Occupied Sched Report | 4 | 2 | 52 | Period(2-6-10-14-18)- stop MM |
| Occupied Sched Report | 5 | 2 | 53 | Period(3-7-11-15-19)- start D |
| Occupied Sched Report | 5 | 2 | 54 | Period(3-7-11-15-19)- start HH |
| Occupied Sched Report | 5 | 2 | 55 | Period(3-7-11-15-19)- start MM |
| Occupied Sched Report | 6 | 2 | 56 | Period(3-7-11-15-19)- stop D |
| Occupied Sched Report | 6 | 2 | 57 | Period(3-7-11-15-19)- stop HH |
| Occupied Sched Report | 6 | 2 | 58 | Period(3-7-11-15-19)- stop MM |
| Occupied Sched Report | 7 | 2 | 59 | Period(4-8-12-16-20)- start D |
| Occupied Sched Report | 7 | 2 | 60 | Period(4-8-12-16-20)- start HH |
| Occupied Sched Report | 7 | 2 | 61 | Period(4-8-12-16-20)- start MM |
| Occupied Sched Report | 8 | 2 | 62 | Period(4-8-12-16-20)- stop D |
| Occupied Sched Report | 8 | 2 | 63 | Period(4-8-12-16-20)- stop HH |
| Occupied Sched Report | 8 | 2 | 64 | Period(4-8-12-16-20)- stop MM |
| Occupied Sched Report | 9 | 2 | 65 | Period(na-na-na-na-21)- start D |
| Occupied Sched Report | 9 | 2 | 66 | Period(na-na-na-na-21)- start HH |

| | | | | |
|-------------------------|-----|-----|-----|---|
| Occupied Sched Report | 9 | 2 | 67 | Period(na-na-na-na-21)- start MM |
| Occupied Sched Report | 10 | 2 | 68 | Period(na-na-na-na-21)- stop D |
| Occupied Sched Report | 10 | 2 | 69 | Period(na-na-na-na-21)- stop HH |
| Occupied Sched Report | 10 | 2 | 70 | Period(na-na-na-na-21)- stop MM |
| | | | | |
| Aux Output Sched Report | N/A | 3 | 271 | Period Number for most recent read Contains a numeric value 1,5,9,13,17 or 21 indicating how the following parameters should be interpreted. |
| | | | 278 | Set to 1 when Period number is 1,2,3,4. Else set to zero by driver |
| | | | 279 | Set to 1 when Period number is 5,6,7,8. Else set to zero by driver |
| | | | 280 | Set to 1 when Period number is 9,10,11,12. Else set to zero by driver |
| | | | 281 | Set to 1 when Period number is 13,14,15,16. Else set to zero by driver |
| | | | 282 | Set to 1 when Period number is 17,18,19,20. Else set to zero by driver |
| | | | 283 | Set to 1 when Period number is 21. Else set to zero by driver |
| Aux Output Sched Report | 1 | 1,3 | 71 | Period(1-5-9-13-17)- start D |
| Aux Output Sched Report | 1 | 1,3 | 72 | Period(1-5-9-13-17)- start HH |
| Aux Output Sched Report | 1 | 1,3 | 73 | Period(1-5-9-13-17)- start MM |
| Aux Output Sched Report | 2 | 1,3 | 74 | Period(1-5-9-13-17)- stop D |
| Aux Output Sched Report | 2 | 1,3 | 75 | Period(1-5-9-13-17)- stop HH |
| Aux Output Sched Report | 2 | 1,3 | 76 | Period(1-5-9-13-17)- stop MM |
| Aux Output Sched Report | 3 | 1,3 | 77 | Period(2-6-10-14-18)- start D |
| Aux Output Sched Report | 3 | 1,3 | 78 | Period(2-6-10-14-18)- start HH |
| Aux Output Sched Report | 3 | 1,3 | 79 | Period(2-6-10-14-18)- start MM |
| Aux Output Sched Report | 4 | 1,3 | 80 | Period(2-6-10-14-18)- stop D |
| Aux Output Sched Report | 4 | 1,3 | 81 | Period(2-6-10-14-18)- stop HH |
| Aux Output Sched Report | 4 | 1,3 | 82 | Period(2-6-10-14-18)- stop MM |
| Aux Output Sched Report | 5 | 1,3 | 83 | Period(3-7-11-15-19)- start D |
| Aux Output Sched Report | 5 | 1,3 | 84 | Period(3-7-11-15-19)- start HH |

| | | | | |
|-------------------------|----|-----|-----|--|
| Aux Output Sched Report | 5 | 1,3 | 85 | Period(3-7-11-15-19)- start MM |
| Aux Output Sched Report | 6 | 1,3 | 86 | Period(3-7-11-15-19)- stop D |
| Aux Output Sched Report | 6 | 1,3 | 87 | Period(3-7-11-15-19)- stop HH |
| Aux Output Sched Report | 6 | 1,3 | 88 | Period(3-7-11-15-19)- stop MM |
| Aux Output Sched Report | 7 | 1,3 | 89 | Period(4-8-12-16-20)- start D |
| Aux Output Sched Report | 7 | 1,3 | 90 | Period(4-8-12-16-20)- start HH |
| Aux Output Sched Report | 7 | 1,3 | 91 | Period(4-8-12-16-20)- start MM |
| Aux Output Sched Report | 8 | 1,3 | 92 | Period(4-8-12-16-20)- stop D |
| Aux Output Sched Report | 8 | 1,3 | 93 | Period(4-8-12-16-20)- stop HH |
| Aux Output Sched Report | 8 | 1,3 | 94 | Period(4-8-12-16-20)- stop MM |
| Aux Output Sched Report | 9 | 1,3 | 95 | Period(na-na-na-na-21)- start D |
| Aux Output Sched Report | 9 | 1,3 | 96 | Period(na-na-na-na-21)- start HH |
| Aux Output Sched Report | 9 | 1,3 | 97 | Period(na-na-na-na-21)- start MM |
| Aux Output Sched Report | 10 | 1,3 | 98 | Period(na-na-na-na-21)- stop D |
| Aux Output Sched Report | 10 | 1,3 | 99 | Period(na-na-na-na-21)- stop HH |
| Aux Output Sched Report | 10 | 1,3 | 100 | Period(na-na-na-na-21)- stop MM |
| | | | | |
| Setpoint Range Report | 1 | | 101 | Occupied temperature- minimum |
| Setpoint Range Report | 2 | | 102 | Occupied temperature- maximum |
| Setpoint Range Report | 3 | | 103 | Unoccupied temperature- minimum |
| Setpoint Range Report | 4 | | 104 | Unoccupied temperature- maximum |
| Setpoint Range Report | 5 | | 105 | Maximum discharge temperature- minimum |
| Setpoint Range Report | 6 | | 106 | Maximum discharge temperature- maximum |
| Setpoint Range Report | 7 | | 107 | Minimum discharge temperature- minimum |
| Setpoint Range Report | 8 | | 108 | Minimum discharge temperature- maximum |
| Setpoint Range Report | 9 | | 109 | Building pressure- minimum |
| Setpoint Range Report | 10 | | 110 | Building pressure- maximum |
| Setpoint Range Report | 11 | | 111 | Occupied burner turnoff- minimum |
| Setpoint Range Report | 12 | | 112 | Occupied burner turnoff- maximum |
| Setpoint Range Report | 13 | | 113 | Unoccupied heater turnoff- minimum |
| Setpoint Range Report | 14 | | 114 | Unoccupied heater turnoff- maximum |
| Setpoint Range Report | 15 | | 115 | Occupied open relief- minimum |
| Setpoint Range Report | 16 | | 116 | Occupied open relief- maximum |

| | | | | |
|--------------------------|----|--|-----|------------------------------------|
| Setpoint Range Report | 17 | | 117 | Unoccupied open relief- minimum |
| Setpoint Range Report | 18 | | 118 | Unoccupied open relief- maximum |
| Setpoint Range Report | 19 | | 119 | Low temperature shutdown- minimum |
| Setpoint Range Report | 20 | | 120 | Low temperature shutdown- maximum |
| Setpoint Range Report | 21 | | 121 | Percent outside air- minimum |
| Setpoint Range Report | 22 | | 122 | Percent outside air- maximum |
| | | | | |
| | | | | |
| | | | | |
| Error reset latch Report | 1 | | 123 | Error log no. 1- error no. |
| Error reset latch Report | 2 | | 124 | Error log no. 1- error no.- Month |
| Error reset latch Report | 2 | | 125 | Error log no. 1- error no.- Day |
| Error reset latch Report | 2 | | 126 | Error log no. 1- error no.- Year |
| Error reset latch Report | 3 | | 127 | Error log no. 1- error no.- Hour |
| Error reset latch Report | 3 | | 128 | Error log no. 1- error no.- Minute |
| Error reset latch Report | 4 | | 129 | Error log no. 2- error no. |
| Error reset latch Report | 5 | | 130 | Error log no. 2- error no.- Month |
| Error reset latch Report | 5 | | 131 | Error log no. 2- error no.- Day |
| Error reset latch Report | 5 | | 132 | Error log no. 2- error no.- Year |
| Error reset latch Report | 6 | | 133 | Error log no. 2- error no.- Hour |
| Error reset latch Report | 6 | | 134 | Error log no. 2- error no.- Minute |
| Error reset latch Report | 7 | | 135 | Error log no. 3- error no. |
| Error reset latch Report | 8 | | 136 | Error log no. 3- error no.- Month |
| Error reset latch Report | 8 | | 137 | Error log no. 3- error no.- Day |
| Error reset latch Report | 8 | | 138 | Error log no. 3- error no.- Year |
| Error reset latch Report | 9 | | 139 | Error log no. 3- error no.- Hour |
| Error reset latch Report | 9 | | 140 | Error log no. 3- error no.- Minute |
| Error reset latch Report | 10 | | 141 | Error log no. 4- error no. |
| Error reset latch Report | 11 | | 142 | Error log no. 4- error no.- Month |
| Error reset latch Report | 11 | | 143 | Error log no. 4- error no.- Day |
| Error reset latch Report | 11 | | 144 | Error log no. 4- error no.- Year |
| Error reset latch Report | 12 | | 145 | Error log no. 4- error no.- Hour |
| Error reset latch Report | 12 | | 146 | Error log no. 4- error no.- Minute |

| | | | | |
|--------------------|----|---|-----|---|
| | | | | |
| Energy information | 1 | | 147 | Last power up date MM |
| Energy information | 1 | | 148 | Last power up date DD |
| Energy information | 1 | | 149 | Last power up date YY |
| Energy information | 2 | | 150 | Last power up time HH |
| Energy information | 2 | | 151 | Last power up time MM |
| Energy information | 3 | | 152 | Number of power ups |
| Energy information | 4 | | 153 | Number of fan starts |
| Energy information | 5 | | 154 | Cumulative fan hours on- thousands |
| Energy information | 6 | | 155 | Cumulative fan hours on- 0-999 |
| Energy information | 7 | | 156 | CCF - thousands (The CCF values have no meaning unless you write meaningful values using the Write version of the Energy Information command. The reason for this is: To read Power Up and Start info the driver has to write the CCF limits. This is done using dummy values and therefore the CCF values in the responses cannot be used.) |
| Energy information | 8 | | 157 | CCF - 0-999 |
| Energy information | 9 | | 158 | CCFH - low rate |
| Energy information | 10 | | 159 | CCFH - min rate |
| Energy information | 11 | | 160 | CCFH - max rate |
| Energy information | 12 | | 161 | High - max rate |
| Energy information | 13 | | 162 | High - current rate |
| | | | | |
| Configuration | 1 | 1 | 238 | Ahu Type: AM- MUA- AR- VAV |
| Configuration | 2 | 1 | 239 | Cooling Type: Vent- Evap- DX- CW |
| Configuration | 3 | 1 | 240 | Burner Type: Gas- None- Heat Coil |
| Configuration | 4 | 1 | 241 | Software Version |
| Configuration | 5 | 1 | 242 | Exhaust(CO) Type: None- Flush Only- Exhaust Only- Both |
| Configuration | 6 | 1 | 243 | Style (ICSII as a 310- or ICSII) |
| Configuration | 7 | 1 | 244 | Rack Size(24/32) |
| Configuration | 8 | 1 | 245 | I/O configuration(12/12-24/8- etc.) |
| Configuration | 9 | 1 | 246 | Jumper Settings (16 total) 1 |

| | | | | |
|---------------|----|---|---------|---|
| Configuration | 9 | 1 | 247 | Jumper Settings (16 total) 2 |
| Configuration | 9 | 1 | 248 | Jumper Settings (16 total) 3 |
| Configuration | 9 | 1 | 249 | Jumper Settings (16 total) 4 |
| Configuration | 9 | 1 | 250 | Jumper Settings (16 total) 5 |
| Configuration | 9 | 1 | 251 | Jumper Settings (16 total) 6 |
| Configuration | 9 | 1 | 252 | Jumper Settings (16 total) 7 |
| Configuration | 9 | 1 | 253 | Jumper Settings (16 total) 8 |
| Configuration | 9 | 1 | 254 | Jumper Settings (16 total) 9 |
| Configuration | 9 | 1 | 255 | Jumper Settings (16 total) 10 |
| Configuration | 9 | 1 | 256 | Jumper Settings (16 total) 11 |
| Configuration | 9 | 1 | 257 | Jumper Settings (16 total) 12 |
| Configuration | 9 | 1 | 258 | Jumper Settings (16 total) 13 |
| Configuration | 9 | 1 | 259 | Jumper Settings (16 total) 14 |
| Configuration | 9 | 1 | 260 | Jumper Settings (16 total) 15 |
| Configuration | 9 | 1 | 261 | Jumper Settings (16 total) 16 |
| Configuration | 10 | 1 | 262 | Future |
| Configuration | 11 | 1 | 263 | Future |
| Configuration | 12 | 1 | 264 | Future |
| | | | | |
| | | 2 | 270 | Scroll up for "Occupied Sched Report" |
| | | 3 | 271 | Scroll up for "Aux Output Sched Report" |
| | | 2 | 272-277 | Scroll up for "Occupied Sched Report" |
| | | 3 | 278-283 | Scroll up for "Aux Output Sched Report" |

Notes

1. This data is not available for ICS1 or 310 systems.

Write Functions

Some commands send more than one parameter / value. If you are using the ‘wr bx’ function to write on change it is recommended that you write the parameters and then set the trigger so that when the command is sent, it is sent with a complete set of data.

| FUNCTION | PARAM | NOTES | DA OFFSET | DESCRIPTION |
|-----------------------------|-------|-------|-----------|---|
| Change Mode | N/A | | 300 | Change Mode Trigger |
| Change Mode | 1 | | 301 | Mode Number |
| Change Setpoint | N/A | 4 | 302 | Change Setpoint Trigger |
| Change Setpoint | 1 | 4 | 303 | Setpoint Number |
| Change Setpoint | 2 | | 304 | Setpoint Value For Pressure, send a value that is 100x the required value. |
| Change Schedule Air Handler | N/A | | 305 | Change Schedule Trigger |
| Change Schedule Air Handler | 1 | | 306 | Period Number |
| Change Schedule Air Handler | 2 | | 307 | Start DD |
| Change Schedule Air Handler | 2 | | 308 | Start HH |
| Change Schedule Air Handler | 2 | | 309 | Start MM |
| Change Schedule Air Handler | 3 | | 310 | Stop DD |
| Change Schedule Air Handler | 3 | | 311 | Stop HH |
| Change Schedule Air Handler | 3 | | 312 | Stop MM |
| Set Aux Output Schedule | N/A | 1 | 313 | Change Schedule Trigger |
| Set Aux Output Schedule | 1 | 1 | 314 | Period Number |
| Set Aux Output Schedule | 2 | 1 | 315 | Start DD |
| Set Aux Output Schedule | 2 | 1 | 316 | Start HH |
| Set Aux Output Schedule | 2 | 1 | 317 | Start MM |
| Set Aux Output Schedule | 3 | 1 | 318 | Stop DD |

| | | | | |
|-------------------------|-----|---|-----|---|
| Set Aux Output Schedule | 3 | 1 | 319 | Stop HH |
| Set Aux Output Schedule | 3 | 1 | 320 | Stop MM |
| | | | | |
| Zero energy counters | N/A | | 321 | Trigger |
| Zero energy counters | 1 | | 322 | Fan Reset |
| Zero energy counters | 2 | | 323 | Gas Reset |
| | | | | |
| Set Aux Output Setpoint | N/A | 1 | 324 | Trigger |
| Set Aux Output Setpoint | 1 | 1 | 325 | Type |
| Set Aux Output Setpoint | 2 | 1 | 326 | Sub-Type |
| Set Aux Output Setpoint | 3 | 1 | 327 | Level |
| | | | | |
| Energy information | N/A | | 328 | Trigger |
| Energy information | 1 | | 329 | CCFH - low rate * 100 |
| Energy information | 2 | | 330 | CCFH - min rate * 100 |
| Energy information | 3 | | 331 | CCFH - max rate * 10 |
| Energy information | 4 | | 332 | CCFH - high rate * 10 |
| Energy information | 5 | | 333 | MINVOLT - voltage value at min lin rate (8 bit 0-255) |
| Energy information | 6 | | 334 | MAXVOLT - voltage value at max lin rate (8-bit 0-255) |
| | | | | |
| Set Date and Time | N/A | | 335 | |
| Set Date and Time | 1 | | 336 | Day of Month (1-31) |
| Set Date and Time | 2 | | 337 | Month (1-12) |
| Set Date and Time | 3 | | 338 | Year (0-99) |
| Set Date and Time | 4 | | 339 | Day of Week (1-7) |
| Set Date and Time | 5 | | 340 | Hours (0-23) |
| Set Date and Time | 6 | | 341 | Minutes (0-59) |
| | | | | |
| | | | | |

Notes

1. This data is not available for ICS1 or 310 systems.

2. This data is multiplexed. Each time the driver reads schedule data it requests the next schedule. Check the value found at offset 270 to determine which period's data has been filled in here. You cannot directly control which period's data is read
3. This data is multiplexed. Each time the driver reads schedule data it requests the next schedule. Check the value found at offset 271 to determine which period's data has been filled in here. You cannot directly control which period's data is read
4. An alternate method is provide. Write directly to addresses 342...

Appendix B.3. FieldServer Node Number

Every node on an ICS1/2 network must have a node number including the FieldServer. The FieldServer's node number is allocated in the configuration file. The following example shows how it is done.

It is permitted to have the same node number for the master (FieldServer) as one of the ICS1/2 controller's.

```
Bridge,  
Title,          System_Node_Id,  
ICSII_Master,  11
```

Appendix C. Troubleshooting Tips

Appendix C.1. Connection Tips & Hints

You could try using the 'ICS_Consume_Nulls' parameter to reduce the effects of noisy RS485 switching or a noisy line. Read 4.2 for more information.

Appendix C.2. Driver Error Messages

The following message may be printed by the driver.

Many problems require that you modify the configuration file. These are marked with a '~'. When you have completed editing the configuration file, download the modified file to the FieldServer and reset the FieldServer for the changes to take effect.

| NO. | MESSAGE | DESCRIPTION AND CORRECTIVE ACTION |
|-----|---|---|
| 1 | ICSII:#1 Err. Bad MD length - defaulting to 1 | The length of the MD must be specified. A table of length's is provided in Appendix B.2 Error! Reference source not found. See note ~ for corrective action. |
| 2 | ICSII:#2 FYI. Reading Everything. MD=%s | This message is informational only. You can safely ignore the message, |
| 3 | ICSII:#3 Err. ICSII_Function invalid. | This message is printed if the ICSII_Function in the configuration file is not recognized. Appendix B.2 provides a list of legal function names. See note ~ for corrective action. |
| 4 | ICSII:#4 Err. Take Log. Call Support. value=%d | If this error occurs rarely then ignore it. It results when a response cannot be interpreted correctly. It is possible that messages get corrupted occasionally. If the error occurs repeatedly then take log and call tech Support. There is no corrective action you can take. |
| 5 | ICSII:#5 FYI. FieldServer is Node=%d on Port=%d | This message is informational only. You can safely ignore the message. The message reports the node number of the FieldServer. All nodes on a ICSII network need a node number including the FieldServer. |

| | | |
|----|---|---|
| | | The FieldServer's node number is defined in the configuration file's 'Bridge' section. Additional notes are provided in Appendix B.3 Error! Reference source not found. |
| 6 | ICSII:#6a Err. Diagnostic. Call support. | Call tech Support. There is no corrective action you can take. |
| 7 | ICSII:#7 Err. Response Appears to come from a MASTER | If this message is printed rarely then you could assume that the message was corrupted. If it occurs often then take a log and call Tech Support. There is no corrective action you can take. |
| 8 | ICSII:#8 Err. Response Func=%d Expected=%d | If this message is printed rarely then you could assume that the message was corrupted. If it occurs often then take a log and call Tech Support. There is no corrective action you can take. |
| 9 | ICSII:#9 Err. Response From Unit#=%d Expected=%d | If this message is printed rarely then you could assume that the message was corrupted. If it occurs often then take a log and call Tech Support. There is no corrective action you can take. |
| 10 | ICSII:#10 Err. Response Func=%d. Unknown. | If this message is printed rarely then you could assume that the message was corrupted. If it occurs often then take a log and call Tech Support. There is no corrective action you can take. |
| 11 | ICSII:#11 Err. Response param count=%d Expected min=%d | If this message is printed rarely then you could assume that the message was corrupted. If it occurs often then take a log and call Tech Support. There is no corrective action you can take. |
| 12 | ICSII:#12 Err. Response param count=%d Max allowed=%d | If this message is printed rarely then you could assume that the message was corrupted. If it occurs often then take a log and call Tech Support. There is no corrective action you can take. |
| 13 | ICSII:#13 FYI. Reading Everything. This Msg=Function#%d | You can safely ignore this message. It tells you what the 'Read All Reports' function is doing at the current time. |
| 14 | ICSII:#14 Err. Driver doest support write thru's. DAoffset=%d | You cannot 'write through a read'. A number of other drivers support the 'write through' technology but this driver does not. This message will be printed when an upstream device writes to a point in a Data Array that is being read from an ICSII controller. Take steps to ensure that the upstream drivers do not do this. |

| | | |
|----|--|--|
| | | <p>To write to the ICS1/2 device, you need to explicitly create 'write' Map Descriptors as shown in examples 3 & 4.</p> |
| 15 | ICSII:#15a FYI. Write abandoned. Trigger not set. | <p>A 'wr bx' write (write on update) was initiated but the trigger value was not set to 1.</p> <p>This happens, if for example you set the length in example 4 to 2 and then had the upstream device set the value of offset 301. In this case, a write would be initiated but the trigger at offset 300 would not have been set yet.</p> <p>Configure the upstream device to write to the trigger offset too and best of all change the length's on wr bx's to 1.</p> |
| 16 | ICSII:#16 Err. DA=%s too short. Rqd=%d Act=%d | <p>The specified array is too short. The required length is printed in the error.</p> <p>Modify the configuration, adjusting the size of the Data Array. See note ~ for corrective action.</p> |
| 17 | ICSII:#17a Err. Parse Err. Failed extracting %d params From <%s> | <p>If this message is printed rarely then you could assume that the message was corrupted. If it occurs often then take a log and call Tech Support. There is no corrective action you can take.</p> |
| 18 | ICSII:#18 Err. Response param length=%d Max allowed=%d | <p>If this message is printed rarely then you could assume that the message was corrupted. If it occurs often then take a log and call Tech Support. There is no corrective action you can take.</p> |
| 19 | ICSII:#19 Err. DA=%s Too small. Rqd Len=%d | <p>The specified array is too short. The required length is printed in the error.</p> <p>Modify the configuration, adjusting the size of the Data Array. See note ~ for corrective action.</p> |
| 20 | ICSII:#20a Err. Parameters could not be extracted. ret=%d | <p>If this message is printed rarely then you could assume that the message was corrupted. If it occurs often then take a log and call Tech Support. There is no corrective action you can take.</p> |
| 21 | ICSII:#21 Err. ret=%d Func=%d buf=%s buf+8=%s | <p>If this message is printed rarely then you could assume that the message was corrupted. If it occurs</p> |

| | | |
|----|--|--|
| | | often then take a log and call Tech Support. There is no corrective action you can take. |
| 22 | | |
| 23 | ICSII:#23 Err. DA=%s too short. Min Length=%d. | <p>The specified array is too short. The required length is printed in the error.</p> <p>Modify the configuration, adjusting the size of the Data Array. See note ~ for corrective action.</p> |
| 24 | | |
| 25 | | |
| 26 | ICSII:#26 Err. DA=%s too short. Rqd=%d Act=%d | <p>The specified array is too short. The required length is printed in the error.</p> <p>Modify the configuration, adjusting the size of the Data Array. See note ~ for corrective action.</p> |
| 27 | ICSII:#27 FYI. ASO Operation. Client Only. | <p>This message is printed when the configuration specifies Application Specific Operation with “Client” as the parameter. Appendix A.1 provides additional information.</p> <p>No corrective action is required.</p> |
| 28 | ICSII:#28 FYI. ASO Operation. Client & Server. | <p>This message should never be printed as this mode is not supported. Read Appendix A.1 and modify your configuration file if necessary. If you cannot eliminate this message then call tech Support.</p> |
| 29 | ICSII:#29 Err. Heading not equal to keywords | <p>This message is printed when the driver create Map Descriptors and Data Arrays as part of the Application Specific Operation (ASO). If the message is printed then not all the MD’s will be created and the ASO will not operate correctly.</p> <p>If this message is printed please review the notes in Appendix A.1 and if necessary call Tech Support.</p> |
| 30 | ICSII:#30 FYI. ASO Operation. DA's and MD's created. | <p>Is you are using Application Specific Operation (ASO) then it is essential that this message gets printed in the error log. It provides confirmation that the Data Arrays and Map Descriptors required for ASO have been created.</p> |

| | | |
|----|--|--|
| | | No corrective action is required when this message is printed. |
| 31 | ICSII:#31 Err. No Date/Time DA. | <p>The ICS server requires a Data Array to store the time sent by a broadcast from the master.</p> <p>Modify the config to create a Data Array called 'ICS_DATE_TIME' with a length of at least 6. Once modified, download the config to the FieldServer and reset the FieldServer for the changes to take effect.</p> |
| 32 | ICSII:#32 Err. Cant unpack date time info. | <p>The message is corrupt and the broadcast date and time message cant be used to update a Data Array. There is no corrective action you can take.</p> |