

# Driver Manual FS-8700-113 PROFIBUS DP Slave

#### **APPLICABILITY & EFFECTIVITY**

Effective for all systems manufactured after April 2021.



fieldserver

Driver Revision: 1.01 Document Revision: 5.A

MSAsafety.com



# fieldserver

MSA Safety 1991 Tarob Court Milpitas, CA 95035 Website: <u>www.MSAsafety.com</u>

U.S. Support Information: +1 408 964-4443 +1 800 727-4377 Email: <u>smc-support@msasafety.com</u>

EMEA Support Information: +31 33 808 0590 Email: <u>smc-support.emea@msasafety.com</u>

## Contents

| 1 | Description4                                                                                                                                                                                                                                                                          |                                         |  |  |
|---|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------------------------------------|--|--|
| 2 | Driver Scope of Supply                                                                                                                                                                                                                                                                | <b>.4</b><br>.4<br>.4<br>.4<br>.4<br>.4 |  |  |
| 3 | Hardware Connections                                                                                                                                                                                                                                                                  | .5                                      |  |  |
|   | 3.1 Hardware Connection Tips / Hints                                                                                                                                                                                                                                                  | .5                                      |  |  |
| 4 | Data Array Parameters                                                                                                                                                                                                                                                                 | .6                                      |  |  |
| 5 | Server Side Configuration5.1PROFIBUS Settings5.1Server Side Connection Descriptions5.2Server Side Node Parameters5.3Server Side Map Descriptor Parameters5.3.1FieldServer Specific Map Descriptor Parameters5.3.2Driver Specific Map Descriptor Parameters5.3.4Map Descriptor Example | .7<br>.7<br>.8<br>.8<br>.8<br>.8<br>.8  |  |  |
| 6 | Useful Features   1     6.1   Setting the FieldServer's PROFIBUS Station Address     6.2   Understanding Driver Communication Statistics                                                                                                                                              | <b>10</b><br>11<br>11                   |  |  |
| 7 | Troubleshooting   1     7.1   Communication Problems   1     7.2   Siemens S7 PLC   1                                                                                                                                                                                                 | <b>12</b><br>12<br>13                   |  |  |

## 1 Description

The FieldServer PROFIBUS DP Slave driver can be used to emulate a single Slave station on a PROFIBUS network. DP Masters can open a connection of up to 244 Bytes of Input and 244 Bytes of Output data, but not exceeding a combined total of 416 Bytes to the FieldServer. The FieldServer can be added to the PROFIBUS network with the use of the supplied GSD file for the ANYBUS<sup>™</sup> card. Connection to the PROFIBUS network is via a DB9 port on the ANYBUS<sup>™</sup> card.

| Max Nodes Supported             |    |                                                            |  |
|---------------------------------|----|------------------------------------------------------------|--|
| FieldServer Mode Nodes Comments |    | Comments                                                   |  |
| Server                          | 32 | The FieldServer can only emulate one PROFIBUS DP Slave sta |  |

#### 2 Driver Scope of Supply

#### 2.1 Supplied by MSA Safety

| Part #     | Description                        |  |
|------------|------------------------------------|--|
| 52201      | PROFIBUS Connector                 |  |
| FS-8915-32 | Adapter Card, Anybus-S PROFIBUS DP |  |
|            | Driver Manual                      |  |

#### 2.2 Additional Files Required

| Filename                | Comments                                                                            |
|-------------------------|-------------------------------------------------------------------------------------|
| Config csv <sup>1</sup> | Template loaded if no custom configuration ordered, otherwise Custom configuration  |
| Connig.csv              | loaded.                                                                             |
| "Anybus                 | The Anybus template gsd file is supplied with the FieldServer and needs to be built |
| gsd file" <sup>2</sup>  | up for the particular application by the Master configuration software.             |

#### 2.3 Provided by the Supplier of 3<sup>rd</sup> Party Equipment

#### 2.3.1 Required 3rd Party Software

PROFIBUS Network Configuration Tool

#### 2.3.2 Required 3<sup>rd</sup> Party Configuration

Connection to a properly terminated PROFIBUS network.

<sup>2</sup> External application.

<sup>&</sup>lt;sup>1</sup> Always loaded by MSA Safety.

#### 3 Hardware Connections

The FieldServer is connected to the PROFIBUS network and NetTool as shown in the connection drawing below.



| PROFIBUS DB9 Connector Pinouts* |                      |                                                    |  |
|---------------------------------|----------------------|----------------------------------------------------|--|
| Pin                             | Name                 | Description                                        |  |
| Housing                         | Shield               | Connected to PE                                    |  |
| 1                               | Not connected        | -                                                  |  |
| 2                               | Not connected        | -                                                  |  |
| 3                               | B-Line               | Positive RxD/TxD according to RS-485 specification |  |
| 4                               | RTS <sup>3</sup>     | Request to send                                    |  |
| 5                               | GND BUS <sup>4</sup> | Isolated GND from RS-485 side                      |  |
| 6                               | +5V BUS4             | Isolated +5V from RS-485 side                      |  |
| 7                               | Not connected        | -                                                  |  |
| 8                               | A-Line               | Negative RxD/TxD according to RS-485 specification |  |
| 9                               | Not connected        | -                                                  |  |

\*Only A-line, B-line and Shield are used for most applications.

| PROFIBUS NetTool Connector Pinouts |                             |  |
|------------------------------------|-----------------------------|--|
| PC Side DB9 Female                 | FieldServer Side DB9 Female |  |
| 2                                  | 3                           |  |
| 3                                  | 2                           |  |
| 5                                  | 5                           |  |

#### 3.1 Hardware Connection Tips / Hints

Use the recommended network cable and terminators as specified by the PROFIBUS network organization and/or the manufacturer of your network equipment.

<sup>&</sup>lt;sup>3</sup> Used in some equipment to determine the direction of transmission.

<sup>&</sup>lt;sup>4</sup> Used for bus termination. Some devices, like optical transceivers (RS-485 to fiber optics), require an external power supply from these pins.

# 4 Data Array Parameters

Data Arrays are "protocol neutral" data buffers for storage of data to be passed between protocols. It is necessary to declare the data format of each of the Data Arrays to facilitate correct storage of the relevant data.

| Section Title      |                                                      |                           |
|--------------------|------------------------------------------------------|---------------------------|
| Data_Arrays        |                                                      |                           |
| Column Title       | Function                                             | Legal Values              |
| Data Array Name    | Brovido namo for Data Array                          | Up to 15 alphanumeric     |
| Data_Anay_Name     | Frovide name for Data Array.                         | characters                |
| Data Array Format  | Provide data format. Each Data Array can only take   | Float, Bit, Byte, Uint16, |
| Dala_Allay_1 Ollia | on one format.                                       | Uint32, Sint16, Sint32    |
|                    | Number of Data Objects. Must be larger than the data |                           |
| Data_Array_Length  | storage area required by the Map Descriptors for the | 1-10000                   |
|                    | data being placed in this array.                     |                           |

#### **Example**

| // Data Arrays  |                     |                     |
|-----------------|---------------------|---------------------|
| Data_Arrays     |                     |                     |
| Data_Array_Name | , Data_Array_Format | , Data_Array_Length |
| DA_AI_01        | , UInt16,           | , 200               |
| DA_AO_01        | , UInt16            | , 200               |
| DA_DI_01        | , Bit               | , 200               |
| DA_DO_01        | , Bit               | , 200               |

### 5 Server Side Configuration

For detailed information on the FieldServer configuration, refer to the FieldServer Configuration Manual. The information that follows describes how to expand upon the factory defaults provided in the configuration files included with the FieldServer (see ".csv" files provided with the FieldServer).

This section documents and describes the parameters necessary for configuring the FieldServer to communicate with a PROFIBUS DP Master.

The configuration file tells the FieldServer about its interfaces, and the routing of data required. In order to enable the FieldServer for PROFIBUS communications, the driver independent FieldServer buffers need to be declared in the "Data Arrays" section, the FieldServer virtual Node(s) needs to be declared in the "Server Side Nodes" section, and the data to be provided to the Clients must be mapped in the "Server Side Map Descriptors" section. Details on how to do this can be found below.

NOTE: In the tables below, \* indicates an optional parameter and bold legal values are defaults.

#### 5.1 **PROFIBUS Settings**

| Section Title           |                                              |              |
|-------------------------|----------------------------------------------|--------------|
| Bridge                  |                                              |              |
| Column Title            | Function                                     | Legal Values |
| System_Station_Address* | PROFIBUS Station Address of the FieldServer. | 1-125        |

NOTE: The PROFIBUS Station Address can also be set via the two rotary switches on the side of the FieldServer in which case the System\_Station\_Address setting must be omitted from the configuration file. The settings specified in the configuration file will override the settings on these switches.

| Admpto      |                          |
|-------------|--------------------------|
| // Bridge   |                          |
| Bridge      |                          |
| Title       | , System_Station_Address |
| PROFIBUS DP | , 5                      |
|             |                          |

#### 5.1 Server Side Connection Descriptions

| Section Title            |               |              |
|--------------------------|---------------|--------------|
| Connections <sup>5</sup> |               |              |
| Column Title             | Function      | Legal Values |
| Adapter                  | Adapter Name. | Prof_DP_MS   |

**Example** 

| // Client Side Connections |
|----------------------------|
| Connections                |
| Adapter                    |
| Prof_DP_MS                 |

<sup>&</sup>lt;sup>5</sup> The FS-B30 PROFIBUS card auto-senses the baud rate.

#### 5.2 Server Side Node Parameters

| Section Title |                        |                                  |
|---------------|------------------------|----------------------------------|
| Nodes         |                        |                                  |
| Column Title  | Function               | Legal Values                     |
| Node_Name     | Provide name for node. | Up to 32 alphanumeric characters |
| Protocol      | Specify protocol used. | Anybus_Prof_DP_S                 |

| Example              |  |  |  |  |  |
|----------------------|--|--|--|--|--|
| // Server Side Nodes |  |  |  |  |  |
| Nodes                |  |  |  |  |  |
| Node_Name , Protocol |  |  |  |  |  |
| CN5 Anybus Prof DP S |  |  |  |  |  |

NOTE: Only one Server Node may be defined for each connection. Contact the sales department for information on support for multiple virtual Server Nodes on a single connection.

#### 5.3 Server Side Map Descriptor Parameters

#### 5.3.1 FieldServer Specific Map Descriptor Parameters

| Column Title        | Function                            | Legal Values                           |  |
|---------------------|-------------------------------------|----------------------------------------|--|
| Map_Descriptor_Name | Name of this Map Descriptor.        | Up to 32 alphanumeric characters       |  |
| Data_Array_Name     | Name of Data Array where data       | One of the Data Array names from "Data |  |
|                     | is to be stored in the FieldServer. | Array" section above                   |  |
| Data Array Offect   | Starting location in Data Array     | 0 to maximum specified in "Data Array" |  |
| Dala_Allay_Oliset   | Starting location in Data Anay.     | section above                          |  |
| Function            | Function of Server Map              | Rdbc, Wrbc                             |  |
|                     | Descriptor.                         |                                        |  |

#### 5.3.2 Driver Specific Map Descriptor Parameters

| Column Title                                  | Function                                               | Legal Values                                                         |  |  |
|-----------------------------------------------|--------------------------------------------------------|----------------------------------------------------------------------|--|--|
| Node_Name                                     | Name of Node to fetch data from.                       | One of the node names specified<br>in "Server Node Descriptor" above |  |  |
| PROFIBUS_Data_Type Data Type of local buffer. |                                                        | Byte, Word, Float, Bool                                              |  |  |
| Address                                       | Byte offset into local buffer.                         | Rdbc: 0 – 243 Wrbc: 0 – 243                                          |  |  |
| Length                                        | Number of PROFIBUS_Data_Type<br>items in local buffer. | Byte: 1 – 244 Word: 1 – 122<br>Float: 1 – 61 Bool: 1 – 1952          |  |  |

NOTE: The combined total length of all Map Descriptors may not exceed 416 bytes.

#### 5.4 Map Descriptor Example

| // Server side Ma | ap Descriptor        |          |                     |              |               |                  |                |
|-------------------|----------------------|----------|---------------------|--------------|---------------|------------------|----------------|
| Map Descriptor    |                      |          |                     |              |               |                  |                |
| Map_Descriptor_N  | Name, Data_Array_Nar | ne, Data | _Array_Offset, Func | tion, Node_N | lame, PROFIBL | JS_Data_Type, Ad | ldress, Length |
| Get_Data          | , Input_Data         | , 0      | , Rdbo              | , Prof_5     | , Word        | , 0              | , 100          |
| Put_Data          | , Output_Data        | , 0.     | , Wrbc              | , Prof_5     | , Word        | , 0              | , 100          |

**Rdbc** - Read function Map Descriptor gets data from the PROFIBUS network and stores it in the Input\_Data Data Array.

**Wrbc** - Write function Map Descriptor puts data from the Output\_Data Data Array onto the PROFIBUS network.

**Address** - Each address refers to an individual local input and output buffer. Each buffer can contain up to 244 bytes, although the combined total is limited to 416 bytes.

# 6 Useful Features



| LED                            | Color | Frequency                                  | Description                                                                                                                                                                                               |  |  |
|--------------------------------|-------|--------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|--|
| Slave<br>Online<br>Status (2)  | Green | - Slave is online on the PROFIBUS network. |                                                                                                                                                                                                           |  |  |
|                                | Off   | -                                          | - Slave is not online on the PROFIBUS network.                                                                                                                                                            |  |  |
| Slave                          | Red   | -                                          | Slave is offline on the PROFIBUS network.                                                                                                                                                                 |  |  |
| Status (3)                     | Off   | -                                          | Slave is not offline on the PROFIBUS network.                                                                                                                                                             |  |  |
| Fieldbus<br>Diagnostics<br>(4) | Red   | 1 Hz                                       | Error in configuration: IN and/or OUT length set<br>during initialization of the Slave is not equal to the<br>length set during configuration of the network.                                             |  |  |
|                                | Red   | 2 Hz                                       | Error in User Parameter data: The length/contents of<br>the User Parameter data set during initialization of<br>the Slave is not equal to the length/contents set<br>during configuration of the network. |  |  |
|                                | Red   | 4 Hz                                       | Error in initialization of the PROFIBUS communication ASIC.                                                                                                                                               |  |  |
|                                | Off   | -                                          | No diagnostics present.                                                                                                                                                                                   |  |  |

#### 6.1 Setting the FieldServer's PROFIBUS Station Address

The Station Address can be set in the FieldServer's CSV file using the System\_Station\_Address, (refer to **Section 5.1**), or it can be set with the two rotary switches as indicated on the connection diagram. The left switch selects the left decimal digit and the right switch the right decimal digit of the Station Address.

# NOTE: The software setting with the System\_Station\_Address overrides the hardware setting with the rotary switches.

#### 6.2 Understanding Driver Communication Statistics

The FieldServer FS-GUI page shows communication statistics displayed on the Connection, Node and Map descriptor screens for the PROFIBUS DP driver.

The Transmit (Tx) message count indicates the number of times the driver wrote output data into the PROFIBUS hardware card's output buffers for transmission on the PROFIBUS network. It does not indicate the actual number of transmissions on the PROFIBUS network.

The Receive (Rx) message count indicates the number of times the driver read input data from the PROFIBUS hardware card's input buffers. It does not indicate the number of actual messages received on the PROFIBUS network.

# 7 Troubleshooting

#### 7.1 Communication Problems

If no communication is being experienced between a PROFIBUS Master and a FieldServer PROFIBUS Slave, check for the following most common issues:

- The Node\_ID must match the System\_Station\_Address in the configuration. Having these two parameters match in the configuration tells the FieldServer that the buffer referenced in the Node\_ID refers to the buffers in the PROFIBUS card attached to the FieldServer.
- The gsd file must match the FieldServer hardware being used.
  - MSA Safety offers several hardware platforms that support PROFIBUS. Each hardware platform requires its own gsd file. Ensure that the gsd file being used is the correct file for the hardware platform in use.
  - The gsd file can be opened with a text editor. The Vendor and model name can be checked in this file. For the FieldServer PROFIBUS Slave, the Vendor is "HMS Industrial Networks AB", and the Model Name is "ANYBUS-S PDP". The current revision is 1.5, which uses Hardware revision 1.6 and software release 1.2.
- The byte count for the gsd profile must match the byte count configured in the FieldServer.
  - The gse being used is either going to allow the Client (via the network configuration tool) to select the bytes to be used, or the byte make-up will be fixed and specified in the gse. Either way, the largest byte offset used by the Client must match the largest byte offset configured in the FieldServer.
  - When selecting byte count with a network configuration tool, the total amount of bytes/words/bits setup per Input/Output buffer in the FieldServer configuration Map Descriptors must match those selected in the network configuration tool otherwise a connection length mismatch will occur and the connection will not be established. The FieldServer shows the connection size it expects on the driver screen under user messages in the FS-GUI in order that this value may be checked against the network configuration tool.
- The direction of the communications (Input/Output Buffer) may be incorrectly configured.
  - Buffer names can be confusing, especially when looking at the Slave. The buffers are named according to their direction of communication in the Master. Hence, an Input buffer in the Slave will write data to the Master, and data will be received from the Master in the output buffer.
  - Remember that as a Slave, the FieldServer will have to write data into the input buffer (function=Wrbc), and read data from the output buffer (function=Rdbc).
- The Data Type/Offset/Length combination may be incorrectly set up.
  - In the FieldServer configuration, the Offset Parameter refers to the buffer offset in bytes (starting at 0), regardless of data type. The Length parameter always refers to length in items, which means Float data will be the number of float values, Word data will be the number of words, etc.
- The PROFIBUS card may be faulty.
  - If this is the case, then there will be an error message in the FieldServer FS-GUI error screen indicating that the card could not be reached. Check for this message. If it is there, try opening up the FieldServer and re-seating the card. If this does not help, technical support for jumper settings on the card, and further possible troubleshooting or return authorization.

#### 7.2 Siemens S7 PLC

If using a Siemens S7 PLC, open the PLC program and follow the screenshots below to change the Consistent over parameter from "Unit" to "Total Length".

| HW Config - [A2_CPU_S03_L10_L20_GD (Configuration) MICRO_A2_GMS_V06_13] Setion Edit Jecot DIC View October Window Holp                                                                                                                                                                                                                                                                                                                                                                |                                                                                                                                                                                           |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| ■ satur tur iser ft ver optons vindor nep<br>□ A 2 ● Mai A iser ft ver optons vindor nep                                                                                                                                                                                                                                                                                                                                                                                              |                                                                                                                                                                                           |
| S3_L10_L20: DP master system (1)     (1)     (1)     (1)     (1)     (1)     (1)     (1)     (1)     (1)     (1)     (1)     (1)     (1)     (2)     (2)     (3)     (4)     (5)     (6)     (7)     (8)     (9)     (10)     (11)     (12)     (12)     (13)     (14)     (15)     (15)     (10)     (10)     (10)     (10)     (10)     (10)     (11)     (12)     (12)     (13)     (14)     (14)     (15)     (15)     (16)     (17)     (18)     (10)     (11)     (11)     (12) | End:<br>End:<br>Profile: Standard<br>PROFIDUS DP<br>PROFIDUS PA<br>B<br>B<br>SIMA TIC 300<br>B<br>SIMA TIC 400<br>B<br>SIMA TIC PC Based Control 300/400<br>B<br>B<br>SIMA TIC PC Station |
|                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       | PROFIDUS-DP slaves for SIMATIC S7, M7, and<br>C7 (distributed rack)                                                                                                                       |

| I | Properties - DP slave                                                                                                |   |  |  |  |  |
|---|----------------------------------------------------------------------------------------------------------------------|---|--|--|--|--|
| 4 | I/O type: Direct Entry                                                                                               |   |  |  |  |  |
| Q | Input<br>Address: Length: Unit: Consistent over:<br>Start: 2612 64 Words Total length<br>End: 2739<br>Process image: |   |  |  |  |  |
|   | Manufacturer-specific data:                                                                                          |   |  |  |  |  |
|   | (Maximum 14 bytes nexadecimal, separated by comma or blank space)                                                    | E |  |  |  |  |
|   | OK Cancel Help                                                                                                       | F |  |  |  |  |